



— Township of —

SEVERN

Water Supply and Distribution System

Coldwater

2022 Summary Report

Contents

- Overview and Background.....3**
 - Safe Drinking Water Act 3
 - Municipal Drinking Water Licensing Program 3
 - System and Process Description 4
 - Source Water 4
 - Raw Water Characteristics..... 4
 - Water Treatment..... 5
 - Water Distribution 5
- Regulatory Compliance5**
 - Regulations 5
 - Ontario Regulation 170/03 6
 - Ontario Regulation 169/03 6
 - Ontario Regulation 128/04 6
 - Wells Regulation 903..... 6
 - Drinking Water Quality Management Standard (DWQMS) 6
 - Municipal Drinking Water License 7
 - Drinking Water Works Permit License 7
 - Non-Compliance and Adverse Water Quality Incidents 7
 - DWQMS and Municipal Drinking Water Licensing Program 7
 - Third Party Audit and Accreditation..... 7
 - Internal Audit..... 7
 - Management Review..... 8



Annual Operations Summary	8
System Improvements and Maintenance	8
Microbiological Testing	9
E. Coli and Total Coliform	9
Heterotrophic Plate Count (HPC)	9
Chlorine Residual and Turbidity.....	10
Chemical Testing.....	10
Understanding Chemical Test Results.....	11
Water Quantity.....	14
Summary of Raw Water Flows	14
Summary of Distribution Flows	15
Flow Charts	16
Appendix A.....	17
Common Acronyms	17
Regulatory and Compliance	17
Parameters and Measurements.....	17
Facilities and Training/Licensing	18
Other.....	18

Overview and Background

Safe Drinking Water Act

Safe Drinking Water Act Ontario Regulation 170/03, Schedule 22-2, requires that owners of municipal drinking water systems prepare a Summary Report and present this report to the members of Municipal Council by March 31st of each year. The report is prepared for the previous calendar year and the following criteria must be included as per the regulation:

- List the requirements of the Act, the regulations, the system's approval, drinking water works permit, municipal drinking water license, and orders applicable to the system that were not met during the period covered by the report.
- For each requirement referred to in clause (a) that was not met specify the duration of the failure and the measures that were taken to correct the failure.
- A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows.
- A comparison of the summary referred to in (c) to the rated capacity and flow rates approved by the system's certificate of approval, drinking water works permit or municipal drinking water license.

This Summary Report also serves as a comprehensive review of the systems performance as it relates to regulations and criteria that fall under the municipal drinking water licensing program.

Municipal Drinking Water Licensing Program

A Municipal Drinking Water License (MDWL) is required in Ontario to operate the drinking water system. The Municipal Drinking Water License (#148-101 Issue Number 3) was re-issued on May 20, 2021 and is valid until May 19, 2026. The reissuance was initiated by the Ministry of Environment, Conservation and Parks



(MECP) due to regulatory amendments that required timelines to be outlined in the MDWL. There are five requirements that must be achieved to obtain an MDWL:

- A valid Drinking Water Works Permit (#148-201 Issue Number 3)
- A valid Permit to Take Water for each source (#06005-8ZSPHN)
- An Operational Plan
- Must have an Accredited Operating Authority (C0124837-DWQ4-C0122097)
- A Financial Plan approved by Council

System and Process Description

The Corporation of the Township of Severn is the owner and operator of the Coldwater Water Supply and Distribution System (DWS# 220001110). It currently has 591 residential and commercial service connections. It also supplies water to Riverwalk Estates distribution system that is comprised of 46 connections. Coldwater is classified as a Class 1 Water Treatment system and a Class 1 Water Distribution system.

Source Water

The Coldwater Water Supply and Distribution System obtains its raw water from any one of two (2) 200mm diameter drilled wells (Well 1 & 3) located on the pump house property or from a 150mm diameter drilled well (Well 2) located across the street from the pump house.

Raw Water Characteristics

The raw water is of low turbidity and is of acceptable ph. Due to the depth of the source water the temperature is relatively constant.

Water Treatment

Water entering the pump house is partially softened with a Kinetico water softener and then filtered using two Calgon model 8 GAC filters operated in series. Filtered water is then disinfected using sodium hypochlorite. Treated water is then stored in an underground reservoir.

Water is pumped to the distribution system via three vertical turbine high lift pumps. A fire pump is also installed to provide adequate flow in the event of a fire. Pressure in the distribution system is maintained at approximately 65 PSI by five 450L pressure tanks.

Online analyzers monitor and record raw and treated water flow rates, treated water turbidity, free chlorine residual and ph. Level sensing probes record well levels. The plant is also equipped with full SCADA control.

Standby power is provided to the building and all its equipment by a 250-kW standby diesel generator.

Water Distribution

The distribution system is comprised of 8.9 km of water main ranging in size from 50 mm to 300 mm. There are 10 sample stations, 5 blow-offs, 83 fire hydrants and 3 private hydrants in the Coldwater system.

Regulatory Compliance

Regulations

All municipally owned and operated water systems are governed under the **Safe Drinking Water Act, 2002**, **Ontario Water Resources Act (OWRA)**, and associated regulations. The following regulations, and associated standards and documents, are all applicable, and most relevant, to the compliant operation of the Township of Severn's Drinking Water system:

Ontario Regulation 170/03

This regulation includes requirements for:

- Sampling and analytical testing (microbiological and chemical)
- Adverse water quality incidents
- Corrective actions
- Continuous water quality monitoring

Ontario Regulation 169/03

This regulation includes requirements for:

- Water Quality Standards

Ontario Regulation 128/04

This regulation includes requirements for:

- Classifications of Drinking Water Systems
- Certifications and responsibilities of Operators
- Proper record keeping of the drinking water system

Wells Regulation 903

This regulation includes requirements for:

- Well maintenance
- Well specifications

Drinking Water Quality Management Standard (DWQMS)

This Standard specifies:

- Minimum requirements for the Quality Management System to allow for the accreditation of the Operating Authority

Municipal Drinking Water License

This document includes requirements for:

- Specific conditions / testing / monitoring
- Flow limits through the treatment system
- Regulatory relief conditions
- Operations and Maintenance manual criteria

Drinking Water Works Permit License

This document includes criteria for:

- Making alterations to the system

Non-Compliance and Adverse Water Quality Incidents

One adverse water quality incident was reported in 2022.

- On September 20, 2022, the Coldwater drinking water system filed a AWQI for loss of pressure. Boil water was implemented do to water main break on Sheppard Street. 15 residential homes were affected.

DWQMS and Municipal Drinking Water Licensing Program

Third Party Audit and Accreditation

On an annual basis, a third-party accreditation authority conducts an audit to determine whether the Quality Management System conforms to the requirements of the MECP Drinking Water Quality Management Standard (DWQMS).

On December 20 and 21, 2022, NSF International completed a satellite audit with no non-conformances noted.

Internal Audit

As per the DWQMS, an internal audit is to be conducted once per year. August 30 to September 1, 2022, an internal audit was conducted by the Aet Group Inc. The findings were included during Management Review.

Management Review

As per the DWQMS, an annual Management Review is to be conducted and findings conveyed to the Owner. Management Review was conducted September 7, 2022. The review included findings from the internal and external audits, MECP inspections and other prescribed items.

Annual Operations Summary

System Improvements and Maintenance

The following maintenance and improvements were carried out in 2022 to provide the highest possible drinking water quality:

- Water distribution system was directionally flushed to maintain the drinking water quality.
- Over 25% of the main valves in the distribution system were exercised to ensure their reliability.
- Standby generator was tested under load monthly to ensure reliability.
- All critical alarms were tested monthly to ensure reliability.
- Drinking water quality was tested at the water treatment plant and in the distribution system weekly.
- New GAC media installed.
- New well pump purchased.

Microbiological Testing

E. Coli and Total Coliform

Bacteriological samples, to be tested for E. Coli and Total Coliforms, are taken weekly from the raw and treated water at the facility and from the distribution system. Extra samples are taken after major repairs or maintenance work as per Regulation 170/03. Any E. Coli or Total Coliform results above 0 in treated water must be reported to the MECP and Medical Officer of Health (MOH). Resamples and other required actions are undertaken as quickly as possible.

The results from the 2022 sampling program are shown on the table below.

Type of Water	Number of Samples	Range of E-Coli Results (cfu/100ml) (Min - Max) MAC=0	Range of Total Coliform Results (cfu/100ml) (Min - Max) MAC=0
Raw	159	0 - 0	0 - 0
Treated	218	0 - 0	0 - 0

Heterotrophic Plate Count (HPC)

HPC analyses are completed weekly from the distribution water for large systems. HPC should be less than 500 colonies (cfu) per 1mL. Results over 500 colonies (cfu) per 1 mL may indicate a change in water quality but it is not considered an indicator of unsafe water.

The results from the 2022 sampling program are shown on the table below.

Type of Water	Number of Samples	Range of HPC Results (cfu/1ml) (Min - Max)
Distribution	156	0 - 40

Chlorine Residual and Turbidity

Free chlorine levels of the treated water are monitored continuously at the discharge point of the treatment facility. In the distribution system, free chlorine is checked twice weekly at various locations. As a target, free chlorine residual within the distribution system should be above 0.20 mg/L. A free chlorine level lower than 0.05 mg/L must be reported to the MECP and corrective action taken. There were no reportable incidents in 2022. The results from the 2022 sampling program are shown on the table below.

Turbidity of treated water is continuously monitored at the treatment facility, as a change in turbidity can indicate an operational problem. Turbidity of the wells are checked monthly. Turbidity is measured in Nephelometric Turbidity Units (NTU).

The results from the 2022 sampling program are shown on the table below.

Parameter	Number of Tests	Range of Results (Min - Max) Average
Chlorine residual in distribution (mg/L)	364	(0.90 - 1.45) 1.19
Chlorine residual after treatment (mg/L)	Continuous	(0.98 - 1.53) 1.26
Turbidity after treatment (NTU)	Continuous	(0.32 - 0.66) 0.48

Chemical Testing

The Safe Drinking Water Act requires periodic testing of the water for different chemical parameters. The latest results are provided below. The sampling frequency varies for different types and sizes of water systems and chemical parameters. If the concentration of a parameter is above half of the Maximum Allowable Concentration (MAC) under the Ontario Drinking Water Quality Standards, an increased testing frequency of once every three months is required by the Regulation. Where concerns regarding a parameter exist, the MECP can also require additional sampling. Information on the health effects and allowable limits of components in drinking water may be found on the MECP web page.

Understanding Chemical Test Results

Tables below are shown with concentrations units of either milligrams per litre (mg/L) or micrograms per litre (µg/L): 1 mg/L is equal to 1000 µg/L. The Maximum Acceptable Concentration (MAC) is the highest amount of a parameter that is acceptable in municipal drinking water and can be found in the MECP Drinking Water Standards. The Method Detection Limit (MDL) is the lowest amount to which the laboratory can confidently measure. A result of “ND” stands for “Not Detected” and means that the concentration of the chemical is lower than the laboratory’s equipment is capable of measuring.

Nitrate and Nitrite samples are required every 3 months in normal operation.

Parameter	Result Range Min - Max	Average	MAC (mg/L)	MDL (mg/L)
Nitrite (mg/L)	0.003 - 0.006	0.004	1	0.003
Nitrate (mg/L)	0.006 - 0.006	0.006	10	0.006

A Trihalomethane (THM) sample is required every 3 months from the distribution system.

Parameter	Annual	Result (Avg.)	MAC (µg/L)	MDL (µg/L)
THM	2022	17.15	100	0.37

A Haloacetic Acid (HAA) sample is required every 3 months from the distribution system.

Parameter	Annual	Result (Avg.)	MAC (µg/L)	MDL (µg/L)
HAA	2022	< 5.3	80	5.3

Summary of the most recent sodium and fluoride results.

Parameter	Sample Date	Result (mg/L)	MAC (mg/L)	MDL (mg/L)
Sodium	2022	93.8	20	0.01
Fluoride	2022	0.10	1.5	0.06

Summary of the most recent lead testing results.

Parameter	Sample Date	Result Range (Min - Max)	Number of samples	Acceptable Level
Distribution Alkalinity	2022	220 - 243 mg/L	28	30-500 mg/L
Distribution pH	2022	7.5 - 7.8	28	6.5-8.5
Distribution Lead	2022	0.01 - 3.88 µg/L	28	10 µg/L

Summary of the most recent Schedule 23/24 testing as per Regulation 170/03

*All results are measured in µg/L unless otherwise stated.

Parameter	Sample Date	Result Value	MAC	MDL
Antimony	Oct. 24, 2022	0.6	6	0.6
Arsenic	Oct. 24, 2022	0.2	10	0.2
Barium	Oct. 24, 2022	252	1000	0.02
Boron	Oct. 24, 2022	74	5000	2
Cadmium	Oct. 24, 2022	0.003	5	0.003
Chromium	Oct. 24, 2022	0.09	50	0.08
Mercury	Oct. 24, 2022	0.01	1	0.01
Selenium	Oct. 24, 2022	0.04	50	0.04
Uranium	Oct. 24, 2022	0.781	20	0.002
Benzene	Oct. 24, 2022	0.32	1	0.32
Carbon tetrachloride	Oct. 24, 2022	0.17	2	0.17
1,2-Dichlorobenzene	Oct. 24, 2022	0.41	200	0.41
1,4-Dichlorobenzene	Oct. 24, 2022	0.36	5	0.36
1,1-Dichloroethylene	Oct. 24, 2022	0.33	14	0.33
1,2-Dichloroethane	Oct. 24, 2022	0.35	5	0.35
Dichloromethane	Oct. 24, 2022	0.35	50	0.35
Monochlorobenzene	Oct. 24, 2022	0.30	80	0.3
Tetrachloroethylene	Oct. 24, 2022	0.35	10	0.35
Trichloroethylene	Oct. 24, 2022	0.44	5	0.44
Vinyl Chloride	Oct. 24, 2022	0.17	1	0.17
Bromoform	Oct. 24, 2022	2.1	--	0.34

Parameter	Sample Date	Result Value	MAC	MDL
Diquat	Oct. 24, 2022	1	70	1
Paraquat	Oct. 24, 2022	1	10	1
Glyphosate	Oct. 24, 2022	1	280	1
PCBs	Oct. 24, 2022	0.04	3	0.04
Benzo(a)pyrene	Oct. 24, 2022	0.004	0.01	0.004
Alachlor	Oct. 24, 2022	0.02	5	0.02
Diazinon	Oct. 24, 2022	0.02	20	0.02
Dimethoate	Oct. 24, 2022	0.06	20	0.06
Diuron	Oct. 24, 2022	0.03	150	0.03
Malathion	Oct. 24, 2022	0.02	190	0.02
Metolachlor	Oct. 24, 2022	0.01	50	0.01
Metribuzin	Oct. 24, 2022	0.02	80	0.02
Phorate	Oct. 24, 2022	0.01	2	0.01
Prometryne	Oct. 24, 2022	0.03	1	0.03
Simazine	Oct. 24, 2022	0.01	10	0.01
Terbufos	Oct. 24, 2022	0.01	1	0.01
Triallate	Oct. 24, 2022	0.01	230	0.01
Trifluralin	Oct. 24, 2022	0.02	45	0.02
2,4-dichlorophenoxyacetic acid	Oct. 24, 2022	0.19	100	0.19
Bromoxynil	Oct. 24, 2022	0.33	5	0.33
Dicamba	Oct. 24, 2022	0.20	120	0.20
Dichlofop-methyl	Oct. 24, 2022	0.40	9	0.40
MCPA (mg/L)	Oct. 24, 2022	0.00012	0.1	0.00012
Picloram	Oct. 24, 2022	<1	190	1
2,4,6-trichlorophenol	Oct. 24, 2022	0.25	5	0.25
2,3,4,6-tetrachlorophenol	Oct. 24, 2022	0.20	100	0.20
Trichloroethylene	Oct. 24, 2022	.44	5	.44

Water Quantity

Continuous monitoring of flow rates from supply wells into the treatment system and from the facility into the distribution system is required by Regulation 170/03. The Municipal Drinking Water License and Permit to Take Water issued by the MECP regulate the amount of water that can be utilized over a given time. A summary of the 2022 flows is provided in the tables below.

Flow Summary	Quantity
Permit to Take Water Limit	Well 1 - 2141 m ³ /day Well 2 - 982.37 m ³ /day Well 3 - 982.37 m ³ /day
Total Taking Limit	2141m ³ /day
Municipal Drinking Water License Limit	3128m ³ /day
2022 Average Daily Flow	408 m ³
2022 Maximum Daily Flow	789 m ³
2022 Total Amount of Water Supplied	148887 m ³

Summary of Raw Water Flows


Month	Well #1 (m ³)	Well #2 (m ³)	Well #3 (m ³)
January	15951	64	70
February	14288	34	37
March	14917	49	63
April	14409	43	49
May	17309	54	59
June	16925	40	44
July	15475	45	48
August	14166	42	45
September	14574	26	28
October	13561	56	61
November	14931	41	44
December	13309	41	44
TOTAL	180940		

Summary of Distribution Flows


Month	Monthly Total (m ³)	Average Daily Flow (m ³ /day)	Minimum Daily Flow (m ³ /day)	Maximum Daily Flow (m ³ /day)
January	13277	428	364	608
February	11919	426	310	789
March	12325	398	317	607
April	11923	397	309	596
May	14516	468	372	758
June	14237	475	331	654
July	12901	416	232	496
August	11839	382	288	550
September	12030	401	318	698
October	11083	358	270	602
November	12215	407	285	564
December	10622	343	241	426
Total	148887			

Flow Charts

Coldwater Monthly Flows Totals (m³)



Coldwater Annual Flow Totals (m³)



Appendix A

Common Acronyms

Regulatory and Compliance

MECP	Ministry of Environment, Conservation and Parks (<i>formerly Ministry of the Environment</i>)
DWQMS	Drinking Water Quality Management System
QMS	Quality Management System
PTTW	Permit to Take Water
MDWL	Municipal Drinking Water License
DWWP	Drinking Water Works Permit
C of A	Certificate of Approval
DWS	Drinking Water System
AWQI	Adverse Water Quality Incident
BWA	Boil Water Advisory
ORO	Overall Responsible Operator
OIC	Operator in Charge
OFI	Opportunity for Improvement
BMP	Best Management Practices

Parameters and Measurements

ppm	parts per million
mg/L	milligrams per litre
µg/L	micrograms per litre
mj/cm²	millijoule per square centimeter
psi	pounds per square inch
w/m²	watt per square meter
THM	Trihalomethane
HAA	Haloacetic Acid
UV	Ultra Violet
CCP	Critical Control Point

Facilities and Training/Licensing

OWWCO	Ontario Water Wastewater Certification Office
WCWC	Walkerton Clean Water Centre
OIT	Operator in Training
WTP	Water Treatment Plant
CEU	Credited Education Units

Other

GAC	Granular Activated Carbon
VFD	Variable Frequency Drive
HL	High Lift (pump)
SCADA	Supervisory Control and Data Acquisition
LL	Low Lift (pump)