



— Township of —

SEVERN

Water Supply and Distribution System

Severn Estates 2020 Annual Report



ANNUAL REPORT

Drinking-Water System Number:	220005152
Drinking-Water System Name:	Severn Estates Water Supply and Distribution
Drinking-Water System Owner:	The Corporation of the Township of Severn
Drinking-Water System Category:	Small Municipal Residential
Period being reported:	January 1, 2020 to December 31, 2020

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Township of Severn Administrative Office 1024 Hurlwood Lane Severn, Ontario L3V 0Y6</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
---	---

Note: For the following tables below, additional rows or columns may be added, or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
Yes [] No []



Indicate how you notified system users that your annual report is available and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____

Describe your Drinking-Water System

Water for the Severn Estates subdivision is pumped from a 69 m deep drilled well located within the Severn Estates pump house at 4532 Trent Trail. Water is chlorinated using sodium hypochlorite for disinfection and for iron precipitation. It is then filtered using a two-train ceramic filter system for iron removal. Filtered water is stored in a 13.6 m³ underground concrete reservoir. Treated water is pumped to the distribution system by two high lift pumps and pressure is maintained by three hydro pneumatic pressure tanks. The Severn Estates water system was constructed in the 1970's of PVC piping. There are two sample stations and three blow offs. There are no fire hydrants connected to the distribution system. It serves 24 homes located on Trent Trail.

List all water treatment chemicals used over this reporting period.

Sodium Hypochlorite

Were any significant expenses incurred to?

- Install required equipment.
- Repair required equipment.
- Replace required equipment.

Please provide a brief description and a breakdown of monetary expenses incurred.

New Roof and access hatch	\$12,000
---------------------------	----------

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
N/A					

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw – Well 1	54	0 – 0	0 – 7	0	N/A
Treated	52	0 – 0	0 – 0	6	0-0
Distribution	52	0 – 0	0 – 0	51	0 – 560

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity – Well 1	12	0.28 – 1.12 NTU
Turbidity	8760	0.16 – 0.68
Chlorine	8760	1.02 – 1.87
Chlorine Free Residual Distribution System	105	0.96 – 1.60
Fluoride (If the DWS provides fluoridation)	N/A	

NOTE: For continuous monitors use 8760 as the number of samples.

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order, or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
July 16, 2020	Cryptosporidium	July 16, 2020	0	N/A
Aug 17, 2020	Cryptosporidium	Aug 17, 2020	0	N/A
September 2, 2020	Cryptosporidium	September 2, 2020	0	N/A

Summary of Inorganic parameters tested during this reporting period or the most recent sample results.

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Oct. 26, 2020	0.09	µg/L	No
Arsenic	Oct. 26, 2020	0.2	µg/L	No
Barium	Oct. 26, 2020	239	µg/L	No
Boron	Oct. 26, 2020	89	µg/L	No
Cadmium	Oct. 26, 2020	0.003	µg/L	No



Chromium	Oct. 26, 2020	0..37	µg/L	No
*Lead	Jan. 27-July 27,2020	0.18-0.67	µg/L	No
Mercury	Oct. 26, 2020	0.01	µg/L	No
Selenium	Oct. 26, 2020	0.10	µg/L	No
Sodium	Oct. 26, 2020	42.5	mg/L	Yes
Uranium	Oct. 26, 2020	0.430	µg/L	No
Fluoride	N/A		mg/L	No
Nitrite	Jan. 27, 2020	0.003	mg/L	No
	Apr. 27, 2020	0.003	mg/L	No
	Jul. 27, 2020	0.003	mg/L	No
	Oct. 26, 2020	0.003	mg/L	No
Nitrate	Jan. 27, 2020	0.046	mg/L	No
	Apr. 27, 2020	0.046	mg/L	No
	Jul. 27, 2020	0.039	mg/L	No
	Oct. 26, 2020	0.037	mg/L	No

*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems.

Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing			
Distribution	2	0.18-0.67	0

Summary of Organic parameters sampled during this reporting period or the most recent sample results.

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Oct. 26, 2020	0.02	µg/L	No
Atrazine + N-dealkylated metabolites	Oct. 26, 2020	0.01	µg/L	No
Azinphos-methyl	Oct. 26, 2020	0.05	µg/L	No
Atrazine	Oct. 26, 2020	0.01	ug/L	No
Azinphos-methyl	Oct. 26, 2020	0.05	ug/L	No
Desethyl atrazine	Oct. 26, 2020	0.01	ug/L	No
Benzene	Oct. 26, 2020	0.32	µg/L	No
Benzo(a)pyrene	Oct. 26, 2020	0.004	µg/L	No
Bromoxynil	Oct. 26, 2020	0.33	µg/L	No
Carbaryl	Oct. 26, 2020	0.05	µg/L	No
Carbofuran	Oct. 26, 2020	0.01	µg/L	No
Carbon Tetrachloride	Oct. 26, 2020	0.17	µg/L	No
Chlorpyrifos	Oct. 26, 2020	0.02	µg/L	No

Dicamba	Oct. 26, 2020	0.20	µg/L	No
1,2-Dichlorobenzene	Oct. 26, 2020	0.41	µg/L	No
1,4-Dichlorobenzene	Oct. 26, 2020	0.36	µg/L	No
1,2-Dichloroethane	Oct. 26, 2020	0.35	µg/L	No
1,1-Dichloroethylene (vinylidene chloride)	Oct. 26, 2020	0.33	µg/L	No
Dichloromethane	Oct. 26, 2020	0.35	µg/L	No
2,4 Dichlorophenol	Oct. 26, 2020	0.15	µg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Oct. 26, 2020	0.19	µg/L	No
Diclofop-methyl	Oct. 26, 2020	0.40	µg/L	No
Diazinon	Oct. 26, 2020	.02	µg/L	
Dimethoate	Oct. 26, 2020	0.06	µg/L	No
Diquat	Oct. 26, 2020	<1	µg/L	No
Diuron	Oct. 26, 2020	0.03	µg/L	No
Glyphosate	Oct. 26, 2020	<1	µg/L	No
Haloacetic Acids (HAA5) (NOTE: show latest annual average)	Average 2020	23.73	µg/L	No
Malathion	Oct. 26, 2020	0.02	µg/L	No
Metolachlor	Oct. 26, 2020	0.01	µg/L	No
Metribuzin	Oct. 26, 2020	0.02	µg/L	No
Monochlorobenzene	Oct. 26, 2020	0.3	µg/L	No
Phorate	Oct. 26, 2020	0.01	µg/L	No
Picloram	Oct. 26, 2020	1	µg/L	No
Polychlorinated Biphenyls (PCB)	Oct. 26, 2020	0.04	µg/L	No
Prometryne	Oct. 26, 2020	0.03	µg/L	No
Simazine	Oct. 26, 2020	0.01	µg/L	No
THM (NOTE: show latest annual average)	Average 2020	69	µg/L	No
Terbufos	Oct. 26, 2020	0.01	µg/L	No
Tetrachloroethylene	Oct. 26, 2020	0.35	µg/L	No
Triallate	Oct. 26, 2020	0.01	µg/L	No
Trichloroethylene	Oct. 26, 2020	0.44	µg/L	No
2,4-Trichlorophenol	Oct. 26, 2020	0.15	µg/L	No
2,4,6-Trichlorophenol	Oct. 26, 2020	0.25	µg/L	No
2,3,4,6 Trichlorophenol	Oct. 26, 2020	0.20	µg/L	No
Trifluralin	Oct. 26, 2020	0.02	µg/L	No
Vinyl Chloride	Oct. 26, 2020	0.17	µg/L	No
MCPA	Oct. 26, 2020	.00012	µg/L	No
Pentachlorophenol	Oct. 26, 2020	0.015	µg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
THMs	69	µg/L	2020 Average
Sodium	42.5	mg/L	October 26, 2020