

— Township of —

**SEVERN**

Water Supply and Distribution System  
**Coldwater**  
**2025 Summary Report**

# Contents

- Overview and Background ..... 3**
  - Safe Drinking Water Act ..... 3
  - Municipal Drinking Water Licensing Program..... 3
  - System and Process Description..... 4
  - Source Water ..... 4
  - Raw Water Characteristics ..... 4
  - Water Treatment..... 5
  - Water Distribution..... 5
- Regulatory Compliance..... 5**
  - Regulations ..... 5
    - Ontario Regulation 170/03 .....6
    - Ontario Regulation 169/03 .....6
    - Ontario Regulation 128/04 .....6
    - Wells Regulation 903 .....6
    - Drinking Water Quality Management Standard (DWQMS) .....6
    - Municipal Drinking Water License .....7
    - Drinking Water Works Permit License.....7
  - Non-Compliance and Adverse Water Quality Incidents..... 7
  - DWQMS and Municipal Drinking Water Licensing Program ..... 7
    - Third-Party Audit and Accreditation.....7
    - Internal Audit .....8
    - Management Review .....8



<b>Annual Operations Summary .....</b>	<b>8</b>
<b>System Improvements and Maintenance.....</b>	<b>8</b>
<b>Microbiological Testing.....</b>	<b>9</b>
E. Coli and Total Coliform .....	9
Heterotrophic Plate Count (HPC) .....	9
Chlorine Residual and Turbidity .....	10
<b>Chemical Testing .....</b>	<b>10</b>
<b>Understanding Chemical Test Results .....</b>	<b>11</b>
<b>Water Quantity.....</b>	<b>14</b>
Summary of Raw Water Flows .....	14
Summary of Distribution Flows.....	15
<b>Flow Charts.....</b>	<b>16</b>
<b>Appendix A .....</b>	<b>17</b>
<b>Common Acronyms.....</b>	<b>17</b>
Regulatory and Compliance .....	17
Parameters and Measurements .....	18
Facilities and Training/Licensing.....	18
Other .....	19

# Overview and Background

## Safe Drinking Water Act

Safe Drinking Water Act Ontario Regulation 170/03, Schedule 22-2, requires that owners of municipal drinking water systems prepare a Summary Report and present this report to the members of Municipal Council by March 31 of each year. The report is prepared for the previous calendar year, and the following criteria must be included as per the regulation:

- List the requirements of the Act, the regulations, the system's approval, drinking water works permit, municipal drinking water license, and orders applicable to the system that were not met during the period covered by the report.
- For each requirement referred to in clause (a) that was not met specify the duration of the failure and the measures that were taken to correct the failure.
- A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows.
- A comparison of the summary referred to in (c) to the rated capacity and flow rates approved by the system's certificate of approval, drinking water works permit or municipal drinking water license.

This Summary Report also serves as a comprehensive review of the system's performance as it relates to regulations and criteria that fall under the municipal drinking water licensing program.

## Municipal Drinking Water Licensing Program

A Municipal Drinking Water License (MDWL) is required in Ontario to operate the drinking water system. The Municipal Drinking Water License (#148-101 Issue Number 3) was re-issued on May 20, 2021, and is valid until May 19, 2026. The reissuance was initiated by the Ministry of Environment, Conservation and Parks



(MECP) due to regulatory amendments that required timelines to be outlined in the MDWL. There are five requirements that must be achieved to obtain an MDWL:

- Valid Drinking Water Works Permit (#148-201 Issue Number 3)
- Valid Permit to Take Water for each source (06005-8ZSPHN)
- An Operational Plan
- Must have an Accredited Operating Authority (C0124837-DWQ6-C0122097)
- A Financial Plan approved by Council

## **System and Process Description**

The Corporation of the Township of Severn is the owner and operator of the Coldwater Water Supply and Distribution System (DWS# 220001110). It currently has 690 residential and commercial service connections. It also supplies water to Riverwalk Estates distribution system that is comprised of 46 connections. Coldwater is classified as a Class 1 Water Treatment system and a Class 1 Water Distribution system.

## **Source Water**

The Coldwater Water Supply and Distribution System obtains its raw water from any one of two (2) 200mm diameter drilled wells (Well 1 & 3) located on the pump house property or from a 150mm diameter drilled well (Well 2) located across the street from the pump house.

## **Raw Water Characteristics**

The raw water is of low turbidity and is of acceptable ph. Due to the depth of the source water the temperature is relatively constant.

## **Water Treatment**

Water entering the pump house is partially softened with a Kinetico water softener and then filtered using two Calgon model 8 GAC filters operated in series. Filtered water is then disinfected using sodium hypochlorite. Treated water is then stored in an underground reservoir.

Water is pumped to the distribution system via three vertical turbine high lift pumps. A fire pump is also installed to provide adequate flow in the event of a fire. Pressure in the distribution system is maintained at approximately 65 pounds-per-square-inch (PSI) by five 450 litre (L) pressure tanks.

Online analyzers monitor and record raw and treated water flow rates, treated water turbidity, free chlorine residual and ph. Level sensing probes record well levels. The plant is also equipped with full SCADA control.

Standby power is provided to the building and all its equipment by a 250 kilowatt (kW) standby diesel generator.

## **Water Distribution**

The distribution system is comprised of 10.4 kilometers (km) of water main ranging in size from 50 millimeters (mm) to 300 mm. There are 13 sample stations, 5 blow-offs, 93 fire hydrants and 3 private hydrants in the Coldwater system.

# **Regulatory Compliance**

## **Regulations**

All municipally owned and operated water systems are governed under the Safe Drinking Water Act, 2002, Ontario Water Resources Act (OWRA), and associated regulations. The following regulations, and associated standards and documents, are all applicable, and most relevant, to the compliant operation of the Township of Severn's Drinking Water system:



### **Ontario Regulation 170/03**

This regulation includes requirements for:

- Sampling and analytical testing (microbiological and chemical)
- Adverse water quality incidents
- Corrective actions
- Continuous water quality monitoring

### **Ontario Regulation 169/03**

This regulation includes requirements for:

- Water Quality Standards

### **Ontario Regulation 128/04**

This regulation includes requirements for:

- Classifications of Drinking Water Systems
- Certifications and responsibilities of Operators
- Proper record keeping of the drinking water system

### **Wells Regulation 903**

This regulation includes requirements for:

- Well maintenance
- Well specifications

### **Drinking Water Quality Management Standard (DWQMS)**

This Standard specifies:

- Minimum requirements for the Quality Management System to allow for the accreditation of the Operating Authority



## **Municipal Drinking Water License**

This document includes requirements for:

- Specific conditions / testing / monitoring
- Flow limits through the treatment system
- Regulatory relief conditions
- Operations and Maintenance manual criteria

## **Drinking Water Works Permit License**

This document includes criteria for:

- Making alterations to the system

## **Non-Compliance and Adverse Water Quality Incidents**

There was one adverse water quality incident in 2025. A water sample was taken with a bacteria exceedance. AWQI was filed and system was resampled with no adverse samples.

## **DWQMS and Municipal Drinking Water Licensing Program**

### **Third-Party Audit and Accreditation**

On an annual basis, a third-party accreditation authority conducts an audit to determine whether the Quality Management System conforms to the requirements of the MECP Drinking Water Quality Management Standard (DWQMS). October 28 and 29, 2025. NSF International completed an onsite audit with no non-conformances noted.



## Internal Audit

As per the DWQMS, an internal audit is to be conducted once per year. September 15 to September 22, 2025, an internal audit was conducted by Acclaims Environmental. One non-conformance was noted, and a full report was included during Management Review.

## Management Review

As per the DWQMS, an annual Management Review is to be conducted, and findings conveyed to the Owner. Management Reviews were conducted March 3, 2025, and October 14, 2025. All elements of the Townships Quality management System were reviewed.

# Annual Operations Summary

The following maintenance and improvements were carried out in 2025 to provide the highest possible drinking water quality:

- The water distribution system was directionally flushed to maintain the drinking water quality.
- Over 25 per cent of the main valves in the distribution system were exercised to ensure their reliability.
- The standby generator was tested under load monthly to ensure reliability.
- All critical alarms were tested monthly to ensure reliability.
- Drinking water quality was tested at the water treatment plant and in the distribution system weekly.
- New GAC media installed.
- 50% of Town was swabbed in 2025 to improve water quality.

## Microbiological Testing

### E. Coli and Total Coliform

Bacteriological samples, to be tested for E. Coli and Total Coliforms, are taken weekly from the raw and treated water at the facility and from the distribution system. Extra samples are taken after major repairs or maintenance work as per Regulation 170/03. Any E. Coli or Total Coliform results above 0 in treated water must be reported to the MECP and Medical Officer of Health (MOH). Resamples and other required actions are undertaken as quickly as possible.

The results from the 2025 sampling program are shown on the table below.

Type of Water	Number of Samples	Range of E-Coli Results (cfu/100ml) (Min - Max) MAC=0	Range of Total Coliform Results (cfu/100ml) (Min - Max) MAC=0
Raw	156	0 - 0	0 - 0
Treated	213	0 - NDOGN	0 - NDOGN

NDOGN-No Data Overgrown

### Heterotrophic Plate Count (HPC)

HPC analyses are completed weekly from the distribution water for large systems. HPC should be less than 500 colonies (cfu) per 1mL. Results over 500 colonies (cfu) per 1 mL may indicate a change in water quality but it is not considered an indicator of unsafe water.

The results from the 2025 sampling program are shown on the table below.

Type of Water	Number of Samples	Range of HPC Results (cfu/1ml) (Min - Max)
Distribution	155	0 - <10

## Chlorine Residual and Turbidity

Free chlorine levels of the treated water are monitored continuously at the discharge point of the treatment facility. In the distribution system, free chlorine is checked twice weekly at various locations. As a target, free chlorine residual within the distribution system should be above 0.20 mg/L. A free chlorine level lower than 0.05 mg/L must be reported to the MECP and corrective action taken. There were no reportable incidents in 2025. The results from the 2025 sampling program are shown on the table below.

Turbidity of treated water is continuously monitored at the treatment facility, as a change in turbidity can indicate an operational problem. Turbidity of the wells is checked monthly. Turbidity is measured in Nephelometric Turbidity Units (NTU).

The results from the 2025 sampling program are shown on the table below.

Parameter	Number of Tests	Range of Results (Min - Max) Average
Chlorine residual in distribution (mg/L)	368	(0.70 - 1.46)
Chlorine residual after treatment (mg/L)	Continuous	(1.00 - 1.54) 1.25
Turbidity after treatment (NTU)	Continuous	(0.09 - 0.41) 0.24

## Chemical Testing

The Safe Drinking Water Act requires periodic testing of the water for different chemical parameters. The latest results are provided below. The sampling frequency varies for different types and sizes of water systems and chemical parameters. If the concentration of a parameter is above half of the Maximum Allowable Concentration (MAC) under the Ontario Drinking Water Quality Standards, an increased testing frequency of once every three months is required by the Regulation. Where concerns regarding a parameter exist, the MECP can also require additional sampling. Information on the health effects and allowable limits of components in drinking water may be found on the MECP web page.

## Understanding Chemical Test Results

Tables below are shown with concentrations units of either milligrams per liter (mg/L) or micrograms per liter ( $\mu\text{g/L}$ ): 1 mg/L is equal to 1000  $\mu\text{g/L}$ . The Maximum Acceptable Concentration (MAC) is the highest amount of a parameter that is acceptable in municipal drinking water and can be found in the MECP Drinking Water Standards. The Method Detection Limit (MDL) is the lowest amount to which the laboratory can confidently measure. The result of "ND" stands for "Not Detected" and means that the concentration of the chemical is lower than the laboratory's equipment is capable of measuring.

Nitrate and Nitrite samples are required every 3 months in normal operation.

Parameter	Result Range Min - Max	Average	MAC (mg/L)	MDL (mg/L)
Nitrite (mg/L)	0.003 - 0.003	0.003	1	0.003
Nitrate (mg/L)	0.006- 0.006	0.006	10	0.006

A Trihalomethane (THM) sample is required every 3 months from the distribution system.

Parameter	Annual	Result (Avg.)	MAC ( $\mu\text{g/L}$ )	MDL ( $\mu\text{g/L}$ )
THM	2025	11.27	100	0.37

A Haloacetic Acid (HAA) sample is required every 3 months from the distribution system.

Parameter	Annual	Result (Avg.)	MAC ( $\mu\text{g/L}$ )	MDL ( $\mu\text{g/L}$ )
HAA	2025	< 5.3	80	5.3



Summary of the most recent sodium, fluoride, and hardness results.

Parameter	Sample Date	Result (mg/L)	MAC (mg/L)	MDL (mg/L)
Sodium	2025	107	20	0.01
Fluoride	2025	0.12	1.5	0.06
Hardness	2025	303	N/A	0.05

Summary of the most recent lead testing results.

Parameter	Sample Date	Result Range (Min - Max)	Number of samples	Acceptable Level
Distribution Alkalinity	2025	231 - 247 mg/L	4	30-500 mg/L
Distribution pH	2025	6.9 - 7.7	4	6.5-8.5
Distribution Lead	2025	0.01 - 0.33 µg/L	4	10 µg/L

Summary of the most recent Schedule 23/24 testing as per Regulation 170/03

\*All results are measured in µg/L unless otherwise stated.

Parameter	Sample Date	Result Value	MAC	MDL
Antimony	Oct. 20, 2025	0.6	6	0.6
Arsenic	Oct. 20, 2025	0.2	10	0.2
Barium	Oct. 20, 2025	253	1000	0.02
Boron	Oct. 20, 2025	54	5000	2
Cadmium	Oct. 20, 2025	0.003	5	0.003
Chromium	Oct. 20, 2025	0.08	50	0.08
Mercury	Oct. 20, 2025	0.01	1	0.01
Selenium	Oct. 20, 2025	0.04	50	0.04
Uranium	Oct. 20, 2025	0.825	20	0.002
Benzene	Oct. 20, 2025	0.32	1	0.32
Carbon tetrachloride	Oct. 20, 2025	0.17	2	0.17
1,2-Dichlorobenzene	Oct. 20, 2025	0.41	200	0.41
1,4-Dichlorobenzene	Oct. 20, 2025	0.36	5	0.36
1,1-Dichloroethylene	Oct. 20, 2025	0.33	14	0.33

Parameter	Sample Date	Result Value	MAC	MDL
1,2-Dichloroethane	Oct. 20, 2025	0.35	5	0.35
Dichloromethane	Oct. 20, 2025	0.35	50	0.35
Monochlorobenzene	Oct. 20, 2025	0.30	80	0.3
Tetrachloroethylene	Oct. 20, 2025	0.35	10	0.35
Trichloroethylene	Oct. 20, 2025	0.44	5	0.44
Vinyl Chloride	Oct. 20, 2025	0.17	1	0.17
Bromoform	Oct. 20, 2025	1.7	--	0.34
Diquat	Oct. 20, 2025	1	70	1
Paraquat	Oct. 20, 2025	1	10	1
Glyphosate	Oct. 20, 2025	1	280	1
PCBs	Oct. 20, 2025	0.04	3	0.04
Benzo(a)pyrene	Oct. 20, 2025	0.004	0.01	0.004
Bromodichloromethane	Oct. 20, 2025	0.63		0.29
Bromoacetic Acid	Oct. 20, 2025	2.9		2.9
Alachlor	Oct. 20, 2025	0.02	5	0.02
Azinphos-methyl	Oct. 20, 2025	0.05	20	0.05
Carbaryl	Oct. 20, 2025	0.05	90	0.05
Carbofuran	Oct. 20, 2025	0.01	90	0.01
Chlorpyrifos	Oct. 20, 2025	0.02	90	0.02
Chloroform	Oct. 20, 2025	0.29		0.29
Chloroacetic Acid	Oct. 20, 2025	4.7		4.7
Diazinon	Oct. 20, 2025	0.02	20	0.02
Dimethoate	Oct. 20, 2025	<1	20	0.06
Diuron	Oct. 20, 2025	0.03	150	0.03
Dibromoacetic Acid	Oct. 20, 2025	2.0		2.0
Dibromochloromethane	Oct. 20, 2025	1.8		0.37
Dichloroacetic Acid	Oct. 20, 2025	2.6		2.6
Malathion	Oct. 20, 2025	0.02	190	0.02
Metolachlor	Oct. 20, 2025	0.01	50	0.01
Metribuzin	Oct. 20, 2025	0.02	80	0.02
Phorate	Oct. 20, 2025	0.01	2	0.01
Prometryne	Oct. 20, 2025	0.03	1	0.03
Pentachlorophenol	Oct. 20, 2025	0.15	60	0.15

Parameter	Sample Date	Result Value	MAC	MDL
Simazine	Oct. 20, 2025	0.01	10	0.01
Terbufos	Oct. 20, 2025	0.01	1	0.01
Triallate	Oct. 20, 2025	0.01	230	0.01
Trifluralin	Oct. 20, 2025	0.02	45	0.02
2,4-dichlorophenoxyacetic Acid	Oct. 20, 2025	0.19	100	0.19
Bromoxynil	Oct. 20, 2025	0.33	5	0.33
Dicamba	Oct. 20, 2025	0.20	120	0.20
Dichlofop-methyl	Oct. 20, 2025	0.40	9	0.40
MCPA (mg/L)	Oct. 20, 2025	0.00012	0.1	0.00012
Picloram	Oct. 20, 2025	<1	190	1
2,4,6-trichlorophenol	Oct. 20, 2025	0.25	5	0.25
2,3,4,6-tetrachlorophenol	Oct. 20, 2025	0.20	100	0.20
Trichloroethylene	Oct. 20, 2025	.44	5	.44

## Water Quantity

Continuous monitoring of flow rates from supply wells into the treatment system and from the facility into the distribution system is required by Regulation 170/03. The Municipal Drinking Water License and Permit to Take Water issued by the MECP regulates the amount of water that can be utilized over a given time. A summary of the 2025 flows is provided in the tables below.

Flow Summary	Quantity
Permit to Take Water Limit	Well 1 - 2141 m <sup>3</sup> /day Well 2 - 982.37 m <sup>3</sup> /day Well 3 - 982.37 m <sup>3</sup> /day
Total Taking Limit	2141m <sup>3</sup> /day
Municipal Drinking Water License Limit	3128m <sup>3</sup> /day
2025 Average Daily Flow	433 m <sup>3</sup>
2025 Maximum Daily Flow	1043 m <sup>3</sup>
2025 Total Amount of Water Supplied	158044 m <sup>3</sup>



### Summary of Raw Water Flows



Month	Well #1 (m <sup>3</sup> )	Well #2 (m <sup>3</sup> )	Well #3 (m <sup>3</sup> )
January	15769	53	61
February	13140	36	39
March	14627	64	66
April	14489	77	85
May	17070	61	63
June	16565	68	74
July	19080	73	76
August	17085	42	43
September	15633	51	
October	15759	43	45
November	14229	42	45
December	14933	72	82
<b>TOTAL</b>	<b>189048</b>		

### Summary of Distribution Flows

Month	Monthly Total (m <sup>3</sup> )	Average Daily Flow (m <sup>3</sup> /day)	Minimum Daily Flow (m <sup>3</sup> /day)	Maximum Daily Flow (m <sup>3</sup> /day)
January	12928	417	305	494
February	10924	390	313	541
March	12063	389	303	447
April	12018	401	324	457
May	14280	461	376	760
June	13920	464	381	545
July	15990	516	400	648
August	14931	482	315	668
September	13224	441	360	554
October	13325	430	314	1043
November	12086	403	331	473
December	12355	399	303	525
<b>Total</b>	<b>158044</b>			

# Flow Charts

\*Note all values are in (m<sup>3</sup>)



# Appendix A

## Common Acronyms

### Regulatory and Compliance

<b>MECP</b>	Ministry of Environment, Conservation and Parks ( <i>formerly Ministry of the Environment</i> )
<b>DWQMS</b>	Drinking Water Quality Management System
<b>QMS</b>	Quality Management System
<b>PTTW</b>	Permit to Take Water
<b>MDWL</b>	Municipal Drinking Water License
<b>DWWP</b>	Drinking Water Works Permit
<b>C of A</b>	Certificate of Approval
<b>DWS</b>	Drinking Water System
<b>AWQI</b>	Adverse Water Quality Incident
<b>BWA</b>	Boil Water Advisory
<b>ORO</b>	Overall Responsible Operator
<b>OIC</b>	Operator in Charge
<b>OFI</b>	Opportunity for Improvement
<b>BMP</b>	Best Management Practices

## Parameters and Measurements

<b>ppm</b>	parts per million
<b>mg/L</b>	milligrams per litre
<b>µg/L</b>	micrograms per litre
<b>mj/cm<sup>2</sup></b>	millijoule per square centimeter
<b>psi</b>	pounds per square inch
<b>w/m<sup>2</sup></b>	watt per square meter
<b>THM</b>	Trihalomethane
<b>HAA</b>	Haloacetic Acid
<b>UV</b>	Ultra Violet
<b>CCP</b>	Critical Control Point

## Facilities and Training/Licensing

<b>OWWCO</b>	Ontario Water Wastewater Certification Office
<b>WCWC</b>	Walkerton Clean Water Centre
<b>OIT</b>	Operator in Training
<b>WTP</b>	Water Treatment Plant
<b>CEU</b>	Credited Education Units

## Other

<b>GAC</b>	Granular Activated Carbon
<b>VFD</b>	Variable Frequency Drive
<b>HL</b>	High Lift (pump)
<b>SCADA</b>	Supervisory Control and Data Acquisition
<b>LL</b>	Low Lift (pump)