



— Township of —

**SEVERN**

Water Supply and Distribution System

# **Sandcastle Estates 2020 Summary Report**

# Contents

- Overview and Background.....3**
  - Safe Drinking Water Act .....3
  - Municipal Drinking Water Licensing Program .....3
  - System and Process Description.....4
  - Source Water .....4
  - Raw Water Characteristics .....5
  - Water Treatment .....5
  - Water Distribution .....5
- Regulatory Compliance .....5**
  - Regulations.....6
    - Ontario Regulation 170/03 .....6
    - Ontario Regulation 169/03 .....6
    - Ontario Regulation 128/04 .....6
    - Wells Regulation 903.....6
    - Drinking Water Quality Management Standard (DWQMS) .....7
    - Municipal Drinking Water License .....7
    - Drinking Water Works Permit License .....7
  - Non-Compliance and Adverse Water Quality Incidents.....7
  - DWQMS & Municipal Drinking Water Licensing Program .....7
    - Third Party Audit and Accreditation .....7
    - Internal Audit .....8
    - Management Review .....8



<b>Annual Operations Summary .....</b>	<b>8</b>
System Improvements and Maintenance .....	8
Microbiological Testing.....	9
E. Coli and Total Coliform .....	9
Heterotrophic Plate Count (HPC) .....	9
Chlorine Residual and Turbidity.....	10
Chemical Testing.....	10
Understanding Chemical Test Results.....	11
Water Quantity.....	14
Summary of Raw Water Flows.....	14
Summary of Distribution Flows.....	15
<b>Appendix A – Flow Charts.....</b>	<b>16</b>

# Overview and Background

## Safe Drinking Water Act

Safe Drinking Water Act Ontario Regulation 170/03, Schedule 22-2, requires that owners of municipal drinking water systems prepare a Summary Report and present this report to the members of Municipal Council by March 31<sup>st</sup> of each year. The report is prepared for the previous calendar year and the following criteria must be included as per the regulation:

- List the requirements of the Act, the regulations, the system's approval, drinking water works permit, municipal drinking water license, and orders applicable to the system that were not met during the period covered by the report.
- For each requirement referred to in clause (a) that was not met specify the duration of the failure and the measures that were taken to correct the failure.
- A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows.
- A comparison of the summary referred to in (c) to the rated capacity and flow rates approved by the system's certificate of approval, drinking water works permit or municipal drinking water license.

This Summary Report also serves as a comprehensive review of the systems performance as it relates to regulations and criteria that fall under the municipal drinking water licensing program.

## Municipal Drinking Water Licensing Program

A Municipal Drinking Water License (MDWL) is required in Ontario to operate the drinking water system. The Municipal Drinking Water License (#148-102 Issue Number 2) was re-issued in May of 2016 and is valid until May 25, 2021. The reissuance was initiated by the Ministry of Environment, Conservation and Parks



(MECP) due to regulatory amendments that required timelines to be outlined in the MDWL. There are five requirements that must be achieved in order to obtain an MDWL:

- A valid Drinking Water Works Permit (#148-202 Issue Number 2)
- A valid Permit to Take Water for each source (#0578-9JFPKZ)
- An Operational Plan
- Must have an Accredited Operating Authority (C0124837-DWQ3-C0122096)
- A Financial Plan approved by Council

## **System and Process Description**

The Corporation of the Township of Severn is the owner and operator of the Sandcastle Estates Water Supply and Distribution System(DWS# 220010654). The system was initially constructed in the early 1970's and was serviced by a well. In 1986 a new water treatment facility was built and Lake Couchiching became the new source of water. It currently has 65 residential service connections. It is classified as a Class 2 Water Treatment system and a Class 2 Water Distribution system.

## **Source Water**

The Sandcastle Estates Water Supply and Distribution System obtain its raw water from Lake Couchiching. The area of Lake Couchiching and Lake Simcoe combined is approximately 76,285ha with a total drainage area of approximately 3,850km<sup>2</sup>. Lake Couchiching is part of the Trent Severn Waterway and is a controlled body of water with monitored water levels. Lake Couchiching has a surface area of 44.75 km<sup>2</sup> with a maximum depth of 12m and a mean depth of 6m. The lake and its immediate watershed are underlain by limestone bedrock in the southern and western areas and with Precambrian bedrock along the northern and eastern areas.



## **Raw Water Characteristics**

The raw water is of low turbidity and is of acceptable pH. The temperature varies widely between summer and winter. Raw water temperature can range from 0.5° Celsius to 25° Celsius.

## **Water Treatment**

The Sandcastle Estates water treatment plant is located at 3992 Sandcastle Court. Raw water is treated through two Culligan Omnifiltration systems. Primary disinfection takes place in the form of ultraviolet treatment. The system also uses sodium hypochlorite for secondary disinfection. Water is delivered to the distribution system by three VFD controlled vertical turbine high lift pumps discharging through a common header. Pressure is maintained with one 450 L pressure tank.

Online analyzers monitor and record raw and treated water flows, chlorine, pH, UV intensity and turbidity values. A level sensing probe records the reservoir level. The plant is equipped with full SCADA control.

A 75 kW propane fueled generator provides backup power to the plant and its equipment.

## **Water Distribution**

The distribution system is comprised of 1.2 km of 50 mm and 100 mm PVC water main. There are 2 sample stations and 3 blow-offs located throughout the system.

# **Regulatory Compliance**

## Regulations

All municipally owned and operated water systems are governed under the Safe Drinking Water Act, 2002, Ontario Water Resources Act (OWRA), and associated regulations. The following regulations, and associated standards and documents, are all applicable, and most relevant, to the compliant operation of the Township of Severn's Drinking Water system:

### Ontario Regulation 170/03

This regulation includes requirements for:

- Sampling and analytical testing (microbiological and chemical)
- Adverse water quality incidents
- Corrective actions
- Continuous water quality monitoring

### Ontario Regulation 169/03

This regulation includes requirements for:

- Water Quality Standards

### Ontario Regulation 128/04

This regulation includes requirements for:

- Classifications of Drinking Water Systems
- Certifications and responsibilities of Operators
- Proper record keeping of the drinking water system

### Wells Regulation 903

This regulation includes requirements for:

- Well maintenance
- Well specifications



## **Drinking Water Quality Management Standard (DWQMS)**

This Standard specifies:

- Minimum requirements for the Quality Management System to allow for the accreditation of the Operating Authority

## **Municipal Drinking Water License**

This document includes requirements for:

- Specific conditions / testing / monitoring
- Flow limits through the treatment system
- Regulatory relief conditions
- Operations & Maintenance manual criteria

## **Drinking Water Works Permit License**

This document includes criteria for:

- Making alterations to the system

## **Non-Compliance and Adverse Water Quality Incidents**

There was one adverse water quality incident that occurred in 2020. December 16, 2020- AWQI was filed for 2 total coliform presents in sample. District health Unit and MECP were notified. System resampled. Resample had 0 total coliform present. AWQI was closed.

## **DWQMS & Municipal Drinking Water Licensing Program**

### **Third Party Audit and Accreditation**

On an annual basis, a third-party accreditation authority conducts an audit to determine whether the Quality Management System conforms to the requirements of the MECP Drinking Water Quality Management Standard (DWQMS).

On November 16 and 17, 2020, NSF International completed a satellite audit with no non-conformances noted.



## **Internal Audit**

As per the DWQMS, an internal audit is to be conducted once per year. October 5-9, 2020 an internal audit was conducted by the Aet Group Inc. The findings were included during Management Review.

## **Management Review**

As per the DWQMS, an annual Management Review is to be conducted and findings conveyed to the Owner. Management Reviews were conducted August 19, 2020 and November 30, 2020. The review included findings from the internal and external audits, MECP inspections and other prescribed items.

# **Annual Operations Summary**

## **System Improvements and Maintenance**

The following maintenance and improvements were carried out in 2020 to provide the highest possible drinking water quality:

- The water distribution system was directionally flushed to maintain the drinking water quality.
- Over 25% of the main valves in the distribution system were exercised to ensure their reliability.
- The standby generator was tested under load monthly to ensure reliability.
- All critical alarms were tested monthly to ensure reliability.
- Drinking water quality was tested at the water treatment plant and in the distribution system weekly.
- New SCADA computer installed.

## Microbiological Testing

### E. Coli and Total Coliform

Bacteriological samples, to be tested for E. Coli and Total Coliforms, are taken weekly from the raw and treated water at the facility and from the distribution system. Extra samples are taken after major repairs or maintenance work as per Regulation 170/03. Any E. Coli or Total Coliform results above 0 in treated water must be reported to the MECP and Medical Officer of Health (MOH). Resamples and other required actions are undertaken as quickly as possible.

The results from the 2020 sampling program are shown on the table below.

	Number of Samples	Range of E-Coli Results (cfu/100ml) (Min - Max) MAC=0	Range of Total Coliform Results (cfu/100ml) (Min - Max) MAC=0
Raw	53	0 - 31	0 - 800
Treated	106	0 - 0	0 - 2

### Heterotrophic Plate Count (HPC)

HPC analyses are completed weekly from the distribution water for small systems. HPC should be less than 500 colonies (cfu) per 1mL. Results over 500 colonies (cfu) per 1 mL may indicate a change in water quality but it is not considered an indicator of unsafe water. The results from the 2020 sampling program are shown on the table below.

The results from the 2020 sampling program are shown on the table below.

	Number of Samples	Range of HPC Results (cfu/1ml) (Min - Max)
Distribution	53	0 - 10



## Chlorine Residual and Turbidity

Free chlorine levels of the treated water are monitored continuously at the discharge point of the treatment facility. In the distribution system, free chlorine is checked twice weekly at various locations. As a target, free chlorine residual within the distribution system should be above 0.20 mg/L. A free chlorine level lower than 0.05 mg/L must be reported to MECP and corrective action taken. There were no reportable incidents in 2020. The results from the 2020 sampling program are shown on the table below.

Turbidity of treated water is continuously monitored at the treatment facility, as a change in turbidity can indicate an operational problem. Turbidity of the source water is checked monthly. Turbidity is measured in Nephelometric Turbidity Units (NTU).

The results from the 2020 sampling program are shown on the table below.

Parameter	Number of Tests	Range of Results (Min - Max) Average
Chlorine residual in distribution (mg/L)	105	(0.98 - 1.64) 1.26
Chlorine residual after treatment (mg/L)	CONTINUOUS	(1.11 - 1.90) 1.45
Turbidity after treatment (NTU)	CONTINUOUS	(0.03 - 0.76) 0.11

## Chemical Testing

The Safe Drinking Water Act requires periodic testing of the water for different chemical parameters. The latest results for all parameters are provided in Appendix A. The sampling frequency varies for different types and sizes of water systems and chemical parameters. If the concentration of a parameter is above half of the Maximum Allowable Concentration (MAC) under the Ontario Drinking Water Quality Standards, an increased testing frequency of once every three months is required by the Regulation. Where concerns regarding a parameter exist, the MECP can also require additional sampling. Information on the health effects and allowable limits of components in drinking water may be found on the MECP web page.

## Understanding Chemical Test Results

Tables below are shown with concentrations units of either milligrams per litre (mg/L) or micrograms per litre ( $\mu\text{g/L}$ ): 1 mg/L is equal to 1000  $\mu\text{g/L}$ . The Maximum Acceptable Concentration (MAC) is the highest amount of a parameter that is acceptable in Municipal drinking water and can be found in the MECP Drinking Water Standards. The Method Detection Limit (MDL) is the lowest amount to which the laboratory can confidently measure. A result of "ND" stands for "Not Detected" and means that the concentration of the chemical is lower than the laboratory's equipment is capable of measuring.

Nitrate and Nitrite samples are required every 3 months in normal operation.

Parameter	Result Range (Min - Max)	Average	MAC (mg/L)	MDL (mg/L)
Nitrite (mg/L)	0.003 - 0.003	0.003	1	0.003
Nitrate (mg/L)	0.021 - 0.140	0.066	10	0.006

A Trihalomethane (THM) sample is required every 3 months from the distribution system

Parameter	Annual	Result (Avg.)	MAC ( $\mu\text{g/L}$ )	MDL ( $\mu\text{g/L}$ )
THM	2020	63.25	100	0.37

A Haloacetic Acid (HAA) sample is required every 3 months from the distribution system

Parameter	Annual	Result (Avg.)	MAC ( $\mu\text{g/L}$ )	MDL ( $\mu\text{g/L}$ )
HAA	2020	37.9	80	0.37

Summary of the most recent sodium and fluoride results

Parameter	Sample Date	Result (mg/L)	MAC (mg/L)	MDL (mg/L)
Sodium	2020	31.8	20	0.01
Fluoride	2018	0.06	1.5	0.06



Summary of the most recent lead testing results

Parameter	Sample Date	Result Range (Min - Max)	Number of samples	Acceptable Level
Distribution Alkalinity	2020	68 - 103 mg/L	2	30 - 500 mg/L
Distribution pH	2020	7.4 - 7.4	2	6.5 - 8.5
Distribution Lead	2020	0.07 - 0.09 µg/L	2	10 µg/L

Summary of the most recent Schedule 23/24 testing as per Regulation 170/03

\*All results are measured in µg/L unless otherwise stated.

Parameter	Sample Date	Result Value	MAC	MDL
Antimony	Oct. 26, 2020	0.09	6	0.02
Arsenic	Oct. 26, 2020	0.3	25	0.2
Barium	Oct. 26, 2020	26.9	1000	0.02
Boron	Oct. 26, 2020	31	5000	0.2
Cadmium	Oct. 26, 2020	0.003	5	0.003
Chromium	Oct. 26, 2020	0.27	50	0.03
Mercury	Oct. 26, 2020	0.01	1	0.01
Selenium	Oct. 26, 2020	0.09	10	0.04
Uranium	Oct. 26, 2020	0.029	20	0.002
Benzene	Oct. 26, 2020	0.32	5	0.32
Carbon tetrachloride	Oct. 26, 2020	0.17	5	0.16
1,2-Dichlorobenzene	Oct. 26, 2020	0.41	200	0.41
1,4-Dichlorobenzene	Oct. 26, 2020	0.36	5	0.36
1,1-Dichloroethylene	Oct. 26, 2020	0.33	14	0.33
1,2-Dichloroethane	Oct. 26, 2020	0.35	5	0.35
Dichloromethane	Oct. 26, 2020	0.35	50	0.35
Monochlorobenzene	Oct. 26, 2020	0.3	80	0.3
Tetrachloroethylene	Oct. 26, 2020	0.35	30	0.35
Trichloroethylene	Oct. 26, 2020	0.44	5	0.44
Vinyl Chloride	Oct. 26, 2020	0.17	2	0.17
Diquat	Oct. 26, 2020	<1	70	1

Parameter	Sample Date	Result Value	MAC	MDL
Paraquat	Oct. 26, 2020	<1	10	1
Glyphosate	Oct. 26, 2020	<1	280	1
PCBs	Oct. 26, 2020	0.04	3	0.04
Benzo(a)pyrene	Oct. 26, 2020	0.004	0.01	0.004
Alachlor	Oct. 26, 2020	0.02	5	0.02
Atrazine+N-daelkylated metabolites	Oct. 26, 2020	0.01	5	0.01
Atrazine	Oct. 26, 2020	0.01	--	0.01
Desethyl atrazine	Oct. 26, 2020	0.01	--	0.01
Azinphos-methyl	Oct. 26, 2020	0.05	20	0.05
Carbaryl	Oct. 26, 2020	0.05	90	0.05
Carbofuran	Oct. 26, 2020	0.01	90	0.01
Chlodane	Oct. 26, 2020	0.01	7	0.01
Chlorpyrifos	Oct. 26, 2020	0.02	90	0.02
Diazinon	Oct. 26, 2020	0.02	20	0.02
Dimethoate	Oct. 26, 2020	0.06	20	0.03
Diuron	Oct. 26, 2020	0.03	150	0.03
Malathion	Oct. 26, 2020	0.02	190	0.02
Methoxychlor	Oct. 26, 2020	0.01	900	0.01
Metolachlor	Oct. 26, 2020	0.01	50	0.01
Metribuzin	Oct. 26, 2020	0.02	80	0.02
Phorate	Oct. 26, 2020	0.01	2	0.01
Prometryne	Oct. 26, 2020	0.03	1	0.03
Simazine	Oct. 26, 2020	0.01	10	0.01
Terbufos	Oct. 26, 2020	0.01	1	0.01
Triallate	Oct. 26, 2020	0.01	230	0.01
Trifluralin	Oct. 26, 2020	0.02	45	0.02
2,4-dichlorophenoxyacetic acid	Oct. 26, 2020	0.19	100	0.19
Bromoxynil	Oct. 26, 2020	0.33	5	0.33
Dicamba	Oct. 26, 2020	0.20	120	0.20
Dichlofop-methyl	Oct. 26, 2020	0.40	9	0.40
MCPA	Oct. 26, 2020	0.00012	0.1	0.00012

Parameter	Sample Date	Result Value	MAC	MDL
Picloram	Oct. 26, 2020	<1	190	1
2,4-dichlorophenol	Oct. 26, 2020	0.15	900	0.15
2,4,6-trichlorophenol	Oct. 26, 2020	.25	5	.25
2,3,4,6-trichlorophenol	Oct. 26, 2020	100	0.2	0.20
Pentachlorophenol	Oct. 26, 2020	0.15	60	0.15

## Water Quantity

Continuous monitoring of flow rates from supply wells into the treatment system and from the facility into the distribution system is required by Regulation 170/03. The Municipal Drinking Water License and Permit to Take Water issued by the MECP regulate the amount of water that can be utilized over a given time period.

A summary of the 2020 flows is provided in the tables below.

FLOW SUMMARY	QUANTITY
Permit to Take Water Limit	388.8 m <sup>3</sup> /day
Municipal Drinking Water License Limit	388.8 m <sup>3</sup> /day
2020 Average Daily Flow	34 m <sup>3</sup> /day
2020 Maximum Daily Flow	68 m <sup>3</sup> /day
2020 Total Amount of Water Supplied	12318 m <sup>3</sup>

### Summary of Raw Water Flows

Month	Monthly Total (m <sup>3</sup> )
January	808
February	812
March	973
April	1048
May	1202
June	1389
July	1554
August	1363

September	1169
October	1152
November	1168
December	1169
<b>TOTAL</b>	<b>13806</b>

### Summary of Distribution Flows

Month	Monthly Total (m3)	Average Daily Flow (m3/day)	Minimum Daily Flow (m3/day)	Maximum Daily Flow (m3/day)
January	676	22	17	28
February	681	23	18	30
March	832	27	19	37
April	938	31	24	36
May	1095	37	24	54
June	1285	43	26	66
July	1396	45	27	68
August	1213	39	30	47
September	1016	34	27	40
October	1034	33	26	39
November	1087	36	28	42
December	1065	34	26	40
<b>Total</b>	<b>12318</b>			

# Appendix A – Flow Charts

