



## ANNUAL REPORT

<b>Drinking-Water System Number:</b>	220005143
<b>Drinking-Water System Name:</b>	Bass Lake Woodlands Water Supply and Distribution
<b>Drinking-Water System Owner:</b>	The Corporation of the Township of Severn
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1, 2024, to December 31, 2024

**Complete if your Category is Large Municipal Residential or Small Municipal Residential**

**Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [X]**

**Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No [ ]**

**Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.**

Township of Severn Administrative Office  
1024 Hurlwood Lane  
Severn, Ontario  
L3V 0Y6

**Complete for all other Categories.**

**Number of Designated Facilities served:**

**Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]**

**Number of Interested Authorities you report to:**

**Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]**

**Note: For the following tables below, additional rows or columns may be added, or an appendix may be attached to the report**

**List all Drinking-Water Systems (if any), which receive all their drinking water from your system:**

<b>Drinking Water System Name</b>	<b>Drinking Water System Number</b>
N/A	

**Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes [ ] No [ ]**



Indicate how you notified system users that your annual report is available and is free of charge.

- ☒ Public access/notice via the web  
☒ Public access/notice via Government Office  
☐ Public access/notice via a newspaper  
☒ Public access/notice via Public Request  
☐ Public access/notice via a Public Library  
☐ Public access/notice via other method \_\_\_\_\_

## Describe your Drinking-Water System

Water for Bass Lake Woodlands comes from three (3) ground water wells located at 1852 Ridley Boulevard. Groundwater is pumped from the well into the pump house where it is chlorinated using sodium hypochlorite. It then travels through a 32 m<sup>3</sup> chlorine contact tank before being stored in a 136 m<sup>3</sup> underground reservoir. Treated water is pumped from the reservoir by three VFD-controlled vertical turbine high lift pumps to the distribution system. The distribution system is comprised of 150 mm PVC water main with copper and PE service lines to the homes. There are four (4) sample stations and three (3) blow-offs located throughout the distribution system. There are no fire hydrants. The system services approximately 162 residential homes in the community Bass Lake Woodlands.

## List all water treatment chemicals used over this reporting period.

Sodium Hypochlorite

## Were any significant expenses incurred to?

- ☐ Install required equipment  
☒ Repair required equipment  
☒ Replace required equipment

## Please provide a brief description and a breakdown of monetary expenses incurred.

Reservoir Inspection-\$3950.00  
Installation of 2 new wells-\$400,000.00  
New dehumidifier-\$15,000.00

## Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
N/A					

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw – Well #1	24	0 - 0	0 – 3	N/A	-
Raw – Well #2	36	0 - 0	0 – 1	N/A	-
Raw – Well #3	48	0 - 0	0 – 7	N/A	-
Treated	53	0 – 0	0 – 0	53	0-10
Distribution	106	0 - 0	0 - 0	106	0 - 10

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity – Well #1	6	0.12 – 0.76 NTU
Turbidity – Well #2	8	0.09 – 0.25 NTU
Turbidity – Well #3	11	0.05 – 0.36 NTU
Turbidity	8760	0.05 – 0.39 NTU
Chlorine	8760	1.05 – 1.53
Chlorine Free Residual Distribution System	368	0.94 – 2.18
Fluoride (If the DWS provides fluoridation)	N/A	

**NOTE:** For continuous monitors use 8760 as the number of samples.

**NOTE:** Record the unit of measure if it is **not** milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A				

Summary of Inorganic parameters tested during this reporting period or the most recent sample results.

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	October 21, 2024	0.6	µg/L	No
Arsenic	October 21, 2024	0.2	µg/L	No
Barium	October 21, 2024	250	µg/L	No
Boron	October 21, 2024	20	µg/L	No
Cadmium	October 21, 2024	0.003	µg/L	No



# Ontario Drinking-Water Systems Regulation O. Reg. 170/03

<b>Chromium</b>	October 21, 2024	1.95	µg/L	No
<b>*Lead</b>	Jan 22-July 22, 2024	0.03-0.04	µg/L	No
<b>Mercury</b>	October 21, 2024	0.01	µg/L	No
<b>Selenium</b>	October 21, 2024	0.05	µg/L	No
<b>Sodium</b>	October 21, 2024	50.3	mg/L	Yes
<b>Uranium</b>	October 21, 2024	0.204	µg/L	No
<b>Fluoride</b>	April 22, 2024	0.06	mg/L	No
<b>Nitrite</b>	January 22, 2024	0.003	mg/L	No
	April 22, 2024	0.003		
	July 22, 2024	0.003		
	Oct. 21, 2024	0.003		
<b>Nitrate</b>	January 22, 2024	1.83	mg/L	No
	April 22, 2024	1.83		
	July 22, 2024	1.44		
	Oct. 21, 2024	1.41		

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems.

## Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
<b>Plumbing</b>	N/A		
<b>Distribution</b>	2	0.03-0.04	NO

## Summary of Organic parameters sampled during this reporting period or the most recent sample results.

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>Alachlor</b>	October 21,2024	0.02	µg/L	No
<b>Atrazine + N-dealkylated metabolites</b>	October 21,2024	0.01	µg/L	No
<b>Atrazine</b>	October 21,2024	0.01	µg/L	No
<b>Azinphos-methyl</b>	October 21,2024	0.05	µg/L	No
<b>Benzene</b>	October 21,2024	0.32	µg/L	No
<b>Benzo(a)pyrene</b>	October 21,2024	0.004	µg/L	No
<b>Bromoxynil</b>	October 21,2024	0.33	µg/L	No
<b>Bromoform</b>	October 21,2024	0.34	µg/L	No
<b>Bromodichloromethane</b>	October 21,2024	3.4	µg/L	No
<b>Bromoacetic Acid</b>	October 21,2024	2.9	µg/L	No
<b>Carbaryl</b>	October 21,2024	0.05	µg/L	No
<b>Carbon tetrachloride</b>	October 21,2024	0.17	µg/L	No
<b>Carbofuran</b>	October 21,2024	0.01	µg/L	No



<b>Chlorpyrifos</b>	October 21,2024	0.02	µg/L	No
<b>Chloroform</b>	October 21,2024	3.6	µg/L	No
<b>Chloroacetic Acid</b>	October 21,2024	4.7	µg/L	No
<b>Diazinon</b>	October 21,2024	0.02	µg/L	No
<b>Dicamba</b>	October 21,2024	0.20	µg/L	No
<b>1,2-Dichlorobenzene</b>	October 21,2024	0.41	µg/L	No
<b>1,4-Dichlorobenzene</b>	October 21,2024	0.36	µg/L	No
<b>1,2-Dichloroethane</b>	October 21,2024	0.35	µg/L	No
<b>1,1-Dichloroethylene (vinylidene chloride)</b>	October 21,2024	0.33	µg/L	No
<b>Dichloromethane</b>	October 21,2024	0.35	µg/L	No
<b>2-4 Dichlorophenol</b>	October 21,2024	0.15	µg/L	No
<b>2,4-Dichlorophenoxy acetic acid (2,4-D)</b>	October 21,2024	0.19	µg/L	No
<b>Diclofop-methyl</b>	October 21,2024	0.40	µg/L	No
<b>Dimethoate</b>	October 21,2024	0.06	µg/L	No
<b>Diquat</b>	October 21,2024	<1	µg/L	No
<b>Diuron</b>	October 21,2024	0.03	µg/L	No
<b>Dibromochloromethane</b>	October 21,2024	2.4	µg/L	No
<b>Dichloroacetic Acid</b>	October 21,2024	2.6	µg/L	No
<b>Dibromoacetic Acid</b>	October 21,2024	2.0	µg/L	No
<b>Desethyl atrazine</b>	October 21,2024	0.01	µg/L	No
<b>Glyphosate</b>	October 21,2024	1	µg/L	No
<b>Haloacetic Acids (HAA5) (NOTE: show latest annual average)</b>	2024 Average	<5.3	µg/L	No
<b>Malathion</b>	October 21,2024	.02	µg/L	No
<b>Metolachlor</b>	October 21,2024	0.01	µg/L	No
<b>Metribuzin</b>	October 21,2024	0.02	µg/L	No
<b>MCPA</b>	October 21,2024	0.00012	mg/L	No
<b>Monochlorobenzene</b>	October 21,2024	0.3	µg/L	No
<b>Paraquat</b>	October 21,2024	<1	µg/L	No
<b>Pentachlorophenol</b>	October 21,2024	0.15	µg/L	No
<b>Phorate</b>	October 21,2024	0.01	µg/L	No
<b>Picloram</b>	October 21,2024	<1	µg/L	No
<b>Polychlorinated Biphenyls (PCB)</b>	October 21,2024	0.04	µg/L	No
<b>Prometryne</b>	October 21,2024	0.03	µg/L	No
<b>Simazine</b>	October 21,2024	0.01	µg/L	No
<b>THM (NOTE: show latest annual average)</b>	2024 Average	8.03	µg/L	No
<b>Terbufos</b>	October 21,2024	0.01	µg/L	No
<b>Tetrachloroethylene</b>	October 21,2024	0.35	µg/L	No
<b>2,3,4,6-Tetrachlorophenol</b>	October 21,2024	0.20	µg/L	No
<b>Triallate</b>	October 21,2024	0.01	µg/L	No
<b>Trichloroethylene</b>	October 21,2024	0.44	µg/L	No
<b>2,4,6-Trichlorophenol</b>	October 21,2024	0.25	µg/L	No
<b>Trifluralin</b>	October 21,2024	0.02	µg/L	No
<b>Trichloroacetic Acid</b>	October 21,2024	5.3	µg/L	No
<b>Vinyl Chloride</b>	October 21,2024	0.17	µg/L	No



**List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

Parameter	Result Value	Unit of Measure	Date of Sample
Sodium	50.3	mg/L	October 21, 2024