



— Township of —

**SEVERN**

Water Supply and Distribution System

# **Coldwater**

# **2021 Annual Report**



**ANNUAL REPORT**

<b>Drinking-Water System Number:</b>	220001110
<b>Drinking-Water System Name:</b>	Coldwater Water Supply and Distribution
<b>Drinking-Water System Owner:</b>	The Corporation of the Township of Severn
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1, 2021 to December 31, 2021

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Township of Severn Administrative Office 1024 Hurlwood Lane Severn, Ontario L3V 0Y6</p> </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]</p> <p>Number of Interested Authorities you report to: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]</p>
---	---

**Note: For the following tables below, additional rows or columns may be added, or an appendix may be attached to the report**

**List all Drinking-Water Systems (if any), which receive all their drinking water from your system:**

Drinking Water System Name	Drinking Water System Number
Riverwalk Estates Drinking Water System	260095277

**Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all its drinking water?**  
Yes [X] No [ ]



Indicate how you notified system users that your annual report is available and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method \_\_\_\_\_

**Describe your Drinking-Water System**

The Coldwater water supply system was built in 1994 to replace the spring water supply west of the village. Water now comes from three (3) drilled groundwater wells. Two are located on the pump house property and the third is across the street from the pump house, on private property. In 2008, an addition was completed to the WTP to house two GAC filters, a softener and a backwash settling tank. Raw water is partially softened before passing through the GAC filters (operated in series). Filtered water is then chlorinated using Sodium Hypochlorite. Treated water is stored in a 1,612 m<sup>3</sup> two-cell, concrete, underground reservoir below the pump house. The reservoir provides the required chlorine contact time to achieve primary disinfection before it is distributed to the residents. The treated water is then pumped from the reservoir to the distribution system via a jockey pump and two (2) vertical turbine pumps. A fire pump is also installed to provide adequate flow in the event of a fire. There are 86 fire hydrants, 10 sampling stations and 5 blow-offs connected to the system. The distribution system is comprised of PVC water mains. The system services approximately 1,400 residents of the Village of Coldwater.

**List all water treatment chemicals used over this reporting period.**

Sodium Hypochlorite  
Softener Salt

**Were any significant expenses incurred to?**

- Install required equipment.
- Repair required equipment.
- Replace required equipment.

**Please provide a brief description and a breakdown of monetary expenses incurred.**

New reservoir sensor-\$5200.00  
Fire flow testing-\$15,000.00.  
New PLC and SCADA-\$62,000.00



Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
N/A					

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Or Fecal Results (min #) - (max #)	Range of Total Coliform Results (min #) - (max #)	Number of HPC Samples	Range of HPC Results (min #) - (max #)
Raw – Well #1	52	0 – 0	0 – 0	N/A	-
Raw – Well #2	52	0 – 0	0 – 13	N/A	-
Raw – Well #3	52	0 – 0	0 – 0	N/A	-
Treated	52	0 – 0	0 – 0	52	0 – 10
Distribution	183	0 – 0	0 – 0	92	0 – 10

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results (min #) - (max #)
Turbidity – Well #1	12	0.06 – 0.17 NTU
Turbidity – Well #2	12	0.09 – 0.32 NTU
Turbidity – Well #3	12	0.09 – 0.19 NTU
Turbidity	8760	0.19 – 0.44 NTU
Chlorine	8760	0.94 – 1.36
Chlorine Free Residual Distribution System	364	0.60 – 1.57
Fluoride (If the DWS provides fluoridation)	1	0.10

*NOTE: For continuous monitors use 8760 as the number of samples.*

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

**Summary of additional testing and sampling - carried out in accordance with the requirement of an approval, order, or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A	TSS	Annual Average	7.23	mg/L

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results.**



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	October,27, 2021	0.6	µg/L	No
Arsenic	October,27, 2021	0.2	µg/L	No
Barium	October,27, 2021	250	µg/L	No
Boron	October,27, 2021	74	µg/L	No
Cadmium	October,27, 2021	0.003	µg/L	No
Chromium	October,27, 2021	0.30	µg/L	No
*Lead	Jan 25-March 30- July 26, 2021	0.02-2.49	Cfu/100mL	No
Mercury	October,27, 2021	0.01	µg/L	No
Selenium	October,27, 2021	0.04	µg/L	No
Sodium	October,27, 2021	109	mg/L	Yes
Uranium	October,27, 2021	0.830	µg/L	No
Fluoride	April 27, 2021	0.10	mg/L	No
Nitrite	January 25, 2021 April 26, 2021 July 26, 2021 October 25, 2021	<0.003 <0.003 <0.003 <0.003	mg/L	No
Nitrate	January 25, 2021 April 26, 2021 July 26, 2021 October 25, 2021	<0.006 <0.006 <0.006 <0.006	mg/L	No

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems.

**Summary of lead testing under Schedule 15.1 during this reporting period**

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing			
Distribution	2	0.02 – .04	0

\*Note: Lead sample results are from the Riverwalk Estates Drinking Water System. DWS# 260095277\*

**Summary of Organic parameters sampled during this reporting period or the most recent sample results.**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	October 28,2021	0.02	µg/L	No



<b>Atrazine + N-dealkylated metabolites</b>	October 28,2021	0.01	µg/L	No
<b>Benzene</b>	October 26,2021	0.32	µg/L	No
<b>Benzo(a)pyrene</b>	October 28,2021	0.004	µg/L	No
<b>Carbaryl</b>	October 28,2021	0.05	µg/L	No
<b>Carbofuran</b>	October 28,2021	0.01	µg/L	No
<b>Chlorpyrifos</b>	October 28,2021	0.02	µg/L	No
<b>Diazinon</b>	October 28,2021	0.02	µg/L	No
<b>Dicamba</b>	Nov 2,2021	0.20	µg/L	No
<b>1,2-Dichlorobenzene</b>	October 26,2021	0.41	µg/L	No
<b>1,4-Dichlorobenzene</b>	October 26,2021	0.36	µg/L	No
<b>1,2-Dichloroethane</b>	October 26,2021	0.35	µg/L	No
<b>1,1-Dichloroethylene (vinylidene chloride)</b>	October 26,2021	0.33	µg/L	No
<b>Dichloromethane</b>	October 26,2021	0.35	µg/L	No
<b>2,4-Dichlorophenoxy acetic acid (2,4-D)</b>	Nov 2,2021	0.19	µg/L	No
<b>Diclofop-methyl</b>	Nov 2,2021	0.40	µg/L	No
<b>Dimethoate</b>	October 28,2021	0.06	µg/L	No
<b>Diquat</b>	Nov 2,2021	<1	µg/L	No
<b>Glyphosate</b>	Nov 1,2021	<1	µg/L	No
<b>Haloacetic Acids (HAA5) (NOTE: show latest annual average)</b>	2021 Average	5.3	µg/L	No
<b>Malathion</b>	October 28,2021	0.02	µg/L	No
<b>Metolachlor</b>	October 28,2021	0.01	µg/L	No
<b>Metribuzin</b>	October 28,2021	0.02	µg/L	No
<b>Monochlorobenzene</b>	October 26,2021	0.35	µg/L	No
<b>Paraquat</b>	Nov 2,2021	<1	µg/L	No
<b>Phorate</b>	October 28,2021	0.01	µg/L	No
<b>Picloram</b>	Nov 2,2021	<1	µg/L	No
<b>Polychlorinated Biphenyls(PCB)</b>	October 29,2021	0.04	µg/L	No
<b>Prometryne</b>	October 28,2021	0.03	µg/L	No
<b>Simazine</b>	October 28,2021	0.01	µg/L	No
<b>THM (NOTE: show latest annual average)</b>	2021 Average	22.25	µg/L	No
<b>Terbufos</b>	October 28,2021	0.01	µg/L	No
<b>Tetrachloroethylene</b>	October 26,2021	0.35	µg/L	No
<b>2,3,4,6-Tetrachlorophenol</b>	Nov 2,2021	0.20	µg/L	No
<b>Triallate</b>	October 28,2021	0.01	µg/L	No
<b>Trichloroethylene</b>	October 26,2021	0.44	µg/L	No
<b>2,4,6-Trichlorophenol</b>	Nov 2,2021	0.25	µg/L	No
<b>Trifluralin</b>	October 28,2021	0.02	µg/L	No
<b>Vinyl Chloride</b>	October 26,2021	0.17	µg/L	No
<b>Carbon tetrachloride</b>	October 26,2021	0.17	µg/L	No
<b>MCPA</b>	Nov 2, 2021	0.00012	µg/L	No
<b>Diuron</b>	October 28,2021	0.03	µg/L	No
<b>Bromoxynil</b>	Nov 2,2021	0.33	µg/L	No
<b>Desethyl atrazine</b>	October 28,2021	0.01	µg/L	No
<b>Azinphos-methyl</b>	October 28,2021	0.05	µg/L	No
<b>Bromoform</b>	October 26,2021	9.5	µg/L	No



# Ontario Drinking-Water Systems Regulation O. Reg. 170/03

Chloriform	October 26,2021	1.2	µg/L	No
------------	-----------------	-----	------	----

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Sodium	109	mg/L	October 25, 2021